

No.

PHED/2026-27/0478

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 23/05/2026

It is certified that an inspection team headed by ..... Mr. Dinesh Kumar (S.I.)

(Name of Officers with designation) from ..... DLWA Lab. PHED

inspected the HEM VIDYA NIKETAN, Chaman Nagaria, Khair, Aligarh

(Name & Address of the school) on ..... (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. ALI/Sch/002/2026-27.. dated 02/05/2026

of District level water Analysis Lab, Aligarh (PHED Lab) certified that


the Hem Vidya Niketan (U.P. Jaj Nigan) (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till .....

 अधिशासी अधिकारी  
नगरपालिका परिषद्

Signature with Seal: स्वैर (अलीगढ़)


Name: NISHAD MADHUR MAY

Designation: E.O.

Name & Address of the Office / Department: .....

To HEM VIDYA NIKETAN,  
VILL - CHAMAN NAGARIA, KHAIR, ALIGARH  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies





District Level Water Analysis Laboratory Aligarh  
Address: First Floor, Office of Superintending Engineer U.P. Jal Nigam (Urban)  
Aligarh 202001

### Water Test Report

Report No:	ALI/Sch /002/2026-27	Issue Date:	02/05/2026
		Page No	01

#### Customer Details

Office Name and Address	HEM VIDYA NIKETAN
Ref Letter No & Date	APP/Testing/30-04-2026

#### Basic details of sample

District	Aligarh	Block	-
Gram Panchayat	-	Village / NPP	-
Habitation	School	Location	Hem Vidya Niketan, Chamar Nagaria, Khair Aligarh (U.P.) 202135
Water Source	R O Water	Sample No.	01
Quantity of Sample	2000 ml	Date of Collection	30/04/2026
Receiving Date	30/04/2026	Sample Collector	Mr. Dinesh Kumar
Sample Depositor	Mr. Dinesh Kumar	Sampling Method	As per IS 17614: Part 1:2021 & APHA 24 <sup>th</sup> Edition
Analysis Start Date	01/05/2026	Analysis Completion Date:	02/05/2026

#### Technical Data of Analysis

S.No	Analyzed parameters	(Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH@25°C	-	7.12	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity	NTU	0.68	1	5	IS 3025 (Pt 10):2023
3	Total Dissolve Solid @180°C	mg/L	108	500	2000	IS 3025 (Pt 16):2023
4	Fluoride	mg/L	0.04	1	1.5	APHA 24 <sup>th</sup> Edition 4500-F Method C (Electrode method) 2023
5	Total Hardness	mg/L	68	200	600	IS 3025 (Part 21):2019
6	Total Alkalinity	mg/L	76	200	600	IS 3025 (Part 23):2023
7	Chloride	mg/L	3.97	250	1000	IS 3025 (Part 32):2019
8	Iron	mg/L	0.005	1	1	APHA 24 <sup>th</sup> Edition 3500-Fe Method B (Phenanthroline Method) 2023
9	Sulphate	mg/L	1.41	200	400	APHA 24 <sup>th</sup> Edition 4500-SO4 Method E (Turbidity Method) 2023
10	Calcium	mg/L	9.62	75	200	IS 3025 (Part 40):2023
11	Magnesium	mg/L	10.7	30	100	IS 3025 (Part 46):2019
12	Nitrate	mg/L	0.68	45	45	APHA 24 <sup>th</sup> Edition 4500-NO3 Method D (UV Screening Method) 2023
13	Colour (Hazen)	-	0	5	15	IS 3025 (Part 4) : 2021
14	Odour	-	Agreeable	-	-	IS 3025 (Part 05):2022
15	Taste	-	Agreeable	-	-	IS 3025 (Part 08):2023

#### Note

1. This Certificate refers only to the sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 10 days (in case of non-perishable items only) from the date of issue of tests reports.
5. Remark- Parameters above permissible limits are written in **Bold**.
6. Sample not Collected by Laboratory.
7. Disclaimer :- Information Provided by Customer (Location, Date of Sample Collection & Name of Sample Collector)
8. Source is not verified by the laboratory.

Reviewed by

*Yashwant Singh*

Yashwant Singh  
(Deputy Technical Manager)

Authorized Signatory

Shailendra Singh  
(Quality Technical Manager)  
02/05/2026  
Quality  
Managed  
Mob-6350499124

Laboratory Contact details  
Email- waterlab.alig@gmail.com